



Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

RC No.1/SPL/MO/PHC/2024/

Dated: 10.05.2024

It is certified that an inspection team headed by **Dr.B. SRINIVAS** MBBS from Medical Officer, PHC, PENAMALURU (Health Department) and Accurate Labs – certified NABL have inspected **Bhashyam Blooms School, Survey No.439/2 at Poranki (V), Penamaluru (M), Krishna District, Andhra Pradesh** on **08-05-2024** and on the basis of Water Test Report (Attached) bearing no **TC8097240000000163F** dated **29-04-2024** from **Accurate Labs, SPIIC block, 3rd floor, Pinnamaneni Polyclinic Road, Siddhartha Nagar, Vijayawada-520 010, A.P. (NABL Lab)** certified that the **Bhashyam Blooms School, Poranki (V), Penamaluru (M), Krishna District, Andhra Pradesh** has safe drinking water facilities for the students and members of staff of the institution. School also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till **1 Year**

Signature

with

Name :

Designation

CIVIL ASST SURGEON

Name & Address of the Office / Department : **MEDICAL & HEALTH**

PHC PENAMALURU

**Community Health Officer
P.H.C. Penamaluru
Krishna Dt. - 521137**

To,
The Principal,
Bhashyam Blooms School,
Survey No.439/2,
Poranki,
Penamaluru Mandal,
Krishna District, AP.

Note: The certificate is to be issued by authorized officer / NABL Lab / local bodies

For **BHASHYAM EDUCATIONAL SOCIETY**

SECRETARY / CORRESPONDENT

**K.maha Lakshmi
PRINCIPAL
BASHYAM BLOOMS**

TEST REPORT

URL:TC8097240000000163F

Issued To : M/s. BHASHYAM BLOOMS			
Address : # NH – 65, Besides Priya Pickles, Poranki, Vijayawada – 521137, Andhra Pradesh			
Reg. No.	2404156	Test Report No.	TR2311137
Date of Registration	23.04.2024	Date of Reporting	29.04.2024
Sample Name	Drinking Water	Start Date	23.04.2024
Sample Quantity	2 Ltr	Completed Date	29.04.2024
Sample Submitted By	Mr. Dhiran 9666286666	Sample Details	NA

TEST RESULTS

S. No.	Test Parameters	Test Method	Unit of Measurement	Result	Specification limits as per 10500:2012	
					Acceptable Limit	Permissible Limit
1.	E.coli	IS 15185:2016	/100ml	Absent	Absent	Absent
2.	Total coliforms	IS 15185:2016	/100ml	Absent	Absent	Absent
3.	Colour	IS 3025 (Part 4):1983	Colour Units	<1.0	Max. 5	Max. 15
4.	Odour	IS 3025 (Part 5):2018	---	Agreeable	Agreeable	Agreeable
5.	Taste	IS 3025(Part 8):1984	---	Agreeable	Agreeable	Agreeable
6.	Turbidity	IS 3025 (Part 10):1984	NTU	<1.0	Max. 1	Max. 5
7.	Total Dissolved Solids	IS 3025 (Part 16):1984	mg/l	89.00	Max. 500	Max. 2000
8.	pH	IS 3025 (Part 11):1983	---	7.96	6.0 - 8.5	6.0 - 8.5
9.	Aluminium	IS 3025 (Part 2):2004	mg/l	<0.03	Max. 0.03	Max. 0.2
10.	Ammonia as N	IS 3025 (Part 34):1988	mg/l	<0.10	Max. 0.5	Max. 0.5
11.	Boron as B	IS 3025 (Part 2):2004	mg/l	<0.10	Max. 0.5	Max. 1.0
12.	Calcium as Ca	IS 3025 (Part 40):2004	mg/l	0.80	Max. 75	Max. 200
13.	Chloride as Cl	EPA-300.0:1993	mg/l	18.15	Max. 250	Max. 1000
14.	Copper	IS 3025 (Part 2):2004	mg/l	<0.03	Max. 0.05	Max. 1.5
15.	Fluoride as F	EPA-300.0:1993	mg/l	<0.10	Max. 1.0	Max. 1.5
16.	Residual free chlorine	IS 3025 (Part 26):1986	mg/l	<0.10	Max. 0.2	Max. 1.0
17.	Iron as Fe	IS 3025 (Part 2):2004	mg/l	<0.10	Max. 0.3	Max. 0.3
18.	Magnesium as Mg	IS 3025 (Part 46):2004	mg/l	6.49	Max. 30	Max. 100
19.	Nitrate as NO ₃	EPA-300.0 :1993	mg/l	<1.0	Max. 45	Max. 45
20.	Sulphate as SO ₄	EPA-300.0:1993	mg/l	<1.0	Max. 200	Max. 400
21.	Sulphide as H ₂ S	IS 3025 (Part 29):1986	mg/l	<0.05	Max. 0.05	Max. 0.05
22.	Alkalinity as CaCO ₃	IS 3025 (Part 23):1986	mg/l	33.98	Max. 200	Max. 600
23.	Total Hardness as CaCO ₃	IS 3025 (Part 21):2009	mg/l	34.00	Max. 200	Max. 600
24.	Chromium as Cr	IS 3025 (Part 2):2004	mg/l	<0.03	Max. 0.05	Max. 0.05

Abbreviations: IS-Indian Standard

Statement of Conformity: The above submitted sample was analysed and results are complied as per Indian Standards IS 10500:2012.

Remarks:

- The results shown in this test report refers only to the sample tested.
- The tested sample is submitted by the customer, unless specifically requested.
- The report shall not be reproduced except in full without approval of the laboratory.



Page 1 of 1

K. Manohar
Authorized Signatory
Name: Mr. K. Manohar
Designation: Chemical Manager

Accurate Labs (NABL ACCREDITED LABORATORY), KVSR Siddhartha College of Pharmaceutical Sciences, SPIIC Block, 3rd Floor, Pinnamaneni Polyclinic Road, Siddhartha Nagar, Vijayawada-520 010, A.P, India.
Ph: 0866-2488744, 6301959631, aefal.labs@gmail.com, info@accuratelabs.in, www. accuratelabs.in

For BHASHYAM EDUCATIONAL SOCIETY

[Signature]
SECRETARY / CORRESPONDENT

K. Maha Lakshmi
PRINCIPAL
BHASHYAM BLOOMS